

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/AUR/2026/09/21

Dated: 02/09/2026

It is certified that an inspection team headed by **AMIT KUMAR QUALITY MANAGER** (Name of Officers with designation) from **DISTRICT LEVEL WATER ANALYSIS LABORATORY – AURAIYA PHED** inspected the **J.B.S. ACADEMY-AURAIYA** on **25/08/2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **AUR/2026/08/21** dated **02/09/2026** of **AURAIYA (PHED Lab)**

certified that the **J.B.S. ACADEMY, GATA NO. 764, MAUZA PADHIN, PARGANA AND DISTRICT AURAIYA, UTTAR PRADESH – 206122** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

VALID TILL – 01/09/2027



Signature with Seal: _____

Name: **AMIT KUMAR**

Designation: **QUALITY MANAGER**

Name & Address of the Office / Department: **UTTAR**

PRADESH JAL NIGAM AURAIYA



To

**J.B.S. ACADEMY, GATA NO. 764, MAUZA PADHIN, PARGANA AND DISTRICT AURAIYA,
UTTAR PRADESH – 206122**

Note: the certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of Executive Engineer, Khand Karyalay
Up Jal Nigam (Rural), Mihauli, Auraiya

Issue No : 00

Issue Date: 17.10.2024

Revision No :-00

Revision Date :00

Test Report Water

Report No.	Aur/2026/08/21	Date	02/09/2026	Page No	74
Customer Details					
Office Name & Address	J.B.S Academy, Parhin, Auraiya.				
Ref. Letter No. & Date	25/08/2026				
Basic Details of Sample					
District	Auraiya	Block	Auraiya		
Gram & Nagar Panchayat	Parhin	Village/City	Parhin		
Habitation	Parhin	Location	Parhin		
Water Source	Submersible pump	Sample No	Aur/25/08/21		
Quantity of Sample	1 lit	Date of S.C	25.08.2026		
Receiving Date	25.08.2026	S. Collector	Mr. INDRJEET		
Sample Depositor	Mr. INDRJEET				
Analysis Start Date	27.08.2026	Analysis Completion Date	31.08.2026		
Environmental Condition					
Temperature	25±3°C	Humidity	50±15%		
Technical Data of Analysis					
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1	Taste	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 1984
2	Odour	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2018
3	Colour	10	5	15	IS 3025 (Part 4): 1983(Platinum Cobalt Visual Comparison Method)
4	Turbidity (NTU)	0.80	1	5	IS3025(Part-10): 2023 (Nephelometric method)
5	PH	7.49	6.5	8.5	IS3025(Part11): 2022 (Electrometric Method)
6	TDS (Mg/L)	482	500	2000	IS3025 (Part 16):2023 Gravimetric Method
7	Alkalinity (Mg/L)	220	200	600	IS3025(Part-23): 2023 (Titration Method)
8	Total Hardness (Mg/L)	320	200	600	IS3025(Part-21): 2019 (Titration Method)
9	Free Residual Chlorine	-	0.0	1	IS 3025(Part 26): 1986
10	Conductivity	-	NA	NA	IS 3025(Part 14): 2013
11	Sulphate (Mg/L)	-	200	400	APHA 23 RD Ed 2017, 4500-SO ₄ (F, Turbidimetric Method)
12	Nitrate (Mg/L)	-	45	No Relaxation	APHA 23 RD Ed 2017, 4500-NO ₃ (B, Ultraviolet Spectrophotometric Screening Method)
13	Fluoride (Mg/L)	-	1.0	No Relaxation	APHA 23 RD Ed 2017, 4500-F (C, Ion Selective Electrode Method)
14	Iron (Mg/L)	-	1.0	No Relaxation	APHA 23 RD Ed 2017, 3500-Fe (B Phenanthroline Method)
15	Chloride (Mg/L)	58	250	1000	IS3025(Part-32): 1988 (Titration Method)
16	Calcium (as Mg), Mg/l	136	75	200	IS 3025 (Part 40): 2019
17	Magnesium (as Mg), Mg/l	44.72	30	100	IS3025(Part-46): 2023
*These Parameters are out of NABL Scope, BDL- Below Detection Limit, NT- Not Tested					
Note	1- This Certificate refers only to the particular sample (s) submitted for testing.				
	2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory				
	3- The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.				
	4- Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified				
	5- Parameters above permissible limit are written in Bold.				
	6- Source is not verified by the Laboratory.				

Prepared by
Atul Kumar
Deputy Quality Manager

Laboratory Contact No. Email

Authorized Signatory
Atul Kumar
Quality Manager

Mob

Quality Manager

Auraiya